



COMMERCIAL ACCESSIBILITY PLAN REVIEW CHECKLIST

INFORMATION	PLAN CHECK NO.:	EXPIRATION DATE:	STATUS:
	PROJECT ADDRESS:		
	WORK DESCRIPTION:		
	APPLICANT'S NAME:	TEL. NO.:	
	ADDRESS:	EMAIL:	
INSTRUCTIONS	<p>Your application for a permit, together with plans and specifications, has been examined and you are advised that the issuance of a permit is withheld for the reasons hereinafter set forth. The approval of plans and specifications does not permit the violation of any sections of the Building Code or other local ordinances or state laws.</p> <p>In an effort to streamline the plan review process, please follow the steps outlined below to ensure that there is no delay in processing your application and reviewing your responses to these plan check comments.</p> <ul style="list-style-type: none"> Comments with circled item numbers apply to this plan check. Revised plans and calculations shall incorporate or address all comments marked on the original checked set of plans, calculations, and this plan review checklist. Provide a written response to each comment and show where and how it has been addressed. Identify the sheet number and detail or reference note on the revised plans where the corrections are made. Time spent searching for the corrected items on the revised plans or calculations will delay the review and approval process. Once all comments on the plans, calculations, and this checklist have been addressed, contact the plan check staff to schedule an appointment to review the changes made. 		
	PLAN REVIEWER: _____ TEL. NO.: (310) 285-_____ ADDRESS: 455 N Rexford Drive, 1 st Floor Beverly Hills, CA 90210		
	EMAIL: _____@beverlyhills.org WEBSITE: www.beverlyhills.org		
	<p>Should you have any questions or need clarification pertaining to the comments made on your project, you may contact the plan check staff by telephone from _____ to _____ M T W TH F.</p> <ul style="list-style-type: none"> Bring the original checked set of plans and calculations along with this checklist to the meeting. Do not schedule an appointment meeting with the plan check staff until all comments have been addressed. Incomplete, indefinite or faded drawings or calculations will not be accepted. 		
NOTE	Numbers within the parenthesis () refer to the section of the applicable code. 2007 Edition of the California Building Code (CBC). Table (T).		



*Publicly funded buildings, structures, sidewalks, curbs and related facilities shall be accessible to and usable by persons with disabilities as follows: Section **109.1.1** Part 2, Title 24, CCR (aka California Building Code).*

1. All buildings, structures, sidewalks, curbs and related facilities constructed in the state by the use of state, county or municipal funds, or the funds of any political subdivision of the state.
2. All buildings, structures, and facilities, which are leased, rented, contracted, sublet or hired by any municipal, county or state division of government, or by a special district.
3. All publicly funded buildings used for congregate residences or for one- or two-family dwelling unit purposes shall conform to the provisions applicable to living accommodations.
4. All existing publicly funded buildings and facilities when alterations, structural repairs or additions are made to such buildings or facilities. For detailed requirements on existing buildings, see Chapter 11B, Division IV, Section 1134B.
5. With respect to buildings, structures, sidewalks, curbs and related facilities not requiring a building permit, building standards published in the California Building Standards Code relating to access for persons with disabilities and other regulations adopted pursuant to Government Code Section 4450, and in effect at the time construction is commenced, shall be applicable.

*All privately funded public accommodations, as defined and commercial facilities, as defined, shall be accessible to persons with disabilities as follows: Section **109.1.2**, Part 2, Title 24, CCR (aka California Building Code).*

Exception: Certain types of privately funded multi-story buildings do not require installation of an elevator to provide access above and below the first floor:

1. Any building, structure, facility, complex or improved area or portions thereof that are used by the general public. Section 109.1.2.1
2. Any sanitary facilities that are made available for public, clients, or employees in such accommodations or facilities. Section 109.1.2.2
3. Any curb or sidewalk intended for public use that is constructed in this State with private funds. Section 109.1.2.3
4. All existing privately funded public accommodations when alterations, structural repairs or additions are made to such public accommodation as set forth under Chapter 11B. Section 109.1.2.4

*All Public Housing and Private Housing available for Public use. **Government Code Sections 4450 and 12955.1(d)***

1. References to section numbers are to Part 2, Title 24, CCR (aka California Building Code). Prefix "3-" is for Part 3, Title 24, CCR (aka California Electrical Code) and "5-" is for Part 5, Title 24, CCR (aka California Plumbing Code). NFPA refers to National Fire Protection Association.
2. Items checked below are required for this project.
3. Exemptions claimed for any item shall be requested in writing and shall include all data needed to determine "unreasonable hardship" as described in Section 202.



The following attached Supplemental Accessibility Regulations correction list(s) is/(are) a part of these corrections:

- Supplemental Checklist No. 1** (Sanitary Facilities, Drinking Fountains, Telephones, Alterations, and Sinks)
- Supplemental Checklist No. 2** (Group "A" Occupancies - Assembly Halls, Dining & Drinking, Etc., Group "E" Occupancies -- Educational Facilities, Group "H" Occupancies - Hazardous Facilities, Group "I" Occupancies, Medical Facilities, and Outdoor Occupancies - Recreational Facilities)
- Supplemental Checklist No. 3** (Group "B" Occupancies_- Office Buildings, Police & Fire Dept. and Courtrooms, Etc.-, Group "M" Occupancies - Sales Facilities -, Factories, Warehouses and ATM's)
- Supplemental Checklist No. 4** (Group "R" Occupancies - Hotels, Motels, Transient Lodging, etc., and Bathing Facilities & Lockers)
- Supplemental Checklist No. 5** (Elevators, Egress and Areas of Refuge, Wheelchair Lifts)
- Residential Accessibility** (Group "R" Occupancies - Covered Multifamily Dwellings Subject to Chapter 11A Regulations)



A. SITE DEVELOPMENT & ACCESSIBLE ROUTE OF TRAVEL

1. Accessible Route of Travel is defined as “a continuous unobstructed path connecting all accessible elements and spaces in an accessible building or facility that can be negotiated by a person with a disability using a wheelchair and that is also safe for and usable by persons with other disabilities, and that is consistent with the definition of “Path of travel”. (1102B)
2. Site development and grading shall be designed to provide access to all entrances and exterior ground floor exits, and access to normal paths of travel, and where necessary to provide access, shall incorporate pedestrian ramps, curb ramps, etc. (1127B.1)
3. At least one accessible route within the boundary of the site shall be provided from public transportation stops, accessible parking and accessible passenger loading zones and public streets or sidewalks to the accessible building entrance they serve. The accessible route shall, to the maximum extent feasible, coincide with the route for the general public. (1114B.1.2)
4. The accessible route of travel shall be the most practical direct route between accessible building entrances, accessible site facilities, and the accessible entrance to the site. If access is provided for pedestrians from a pedestrian tunnel or elevated walkway, entrances to the building from each tunnel or walkway must be accessible. (1127B.1)
5. When more than one building or facility is located on a site, accessible routes of travel complying with Section 1114B.1.2 shall be provided between buildings and accessible site facilities, accessible elements, and accessible spaces that are on the same site. (1127B.1)
6. When a building or portion of a building is required to be accessible or adaptable, an accessible route of travel complying with Sections 1102B, 1114B, 1124B, 1133B.3, 1133B.5, 1133B.7 and 1133B.8.6 shall be provided to all portions of the building, to accessible building entrances, and between the building and the public way. (1114B.1.2)

7. Except within an individual dwelling unit, an accessible route of travel shall not pass through kitchens, storage rooms, restrooms, closets or other spaces used for similar purposes. (1114B.1.2)
8. At least one accessible route shall connect the following: (1114B.1.2)
 - a. Accessible buildings, facilities, elements and spaces that are on the same site.
 - b. Accessible building or facility entrances with all accessible spaces and elements and with all accessible dwelling units within the building or facility.
 - c. The accessible route shall, to the maximum extent feasible coincide with the route for the general public.
 - d. Accessible entrance of each accessible dwelling unit with those exterior and interior spaces and facilities that serve the accessible dwelling unit.
9. Where more than one route of travel is provided, all routes shall be accessible. (1114B.1.2)

B. ACCESSIBLE PARKING

1. Each lot or parking structure where parking is provided for the public as clients, guests or employees, shall provide accessible parking as required by Section 1129B. (1129B.1)
2. Provide disabled parking spaces as required by Table 11B-6 for parking lot/structure. (1129B.1)

Total # of parking spaces provided	Minimum # of accessible spaces required
1-25	1
26-50	2
51-75	3
76-100	4
101-150	5
151-200	6
201-300	7
301-400	8
401- 500	9
501-1000	2% of total
1001 & over	20 plus one for each 100 or fraction thereof over 1,001

3. At facilities providing medical care and other services for persons with mobility impairments, parking spaces



- complying with Section 1129B shall be provided in accordance with Table 11B-6, except as follows: (1129B.2)
- a. Outpatient units and facilities: 10% of the total number of parking spaces provided serving each such outpatient unit or facility. (1129B.2.1)
 - b. Units and facilities that specialize in treatment or services for persons with mobility impairments: 20% of the total number of parking spaces provided serving each such unit or facility. (1129B.2.2)
4. Accessible parking spaces serving a particular building shall be located on the shortest accessible route of travel from adjacent parking to an accessible entrance (as near as practical to an accessible entrance). (1129B.1)
 5. In parking facilities that do not serve a particular building, accessible parking shall be located on the shortest accessible route of travel to an accessible pedestrian entrance of the parking facility. (1129B.1)
 6. In buildings with multiple accessible entrances with adjacent parking, accessible parking spaces shall be dispersed and located closest to the accessible entrances. (1129B.1)
 7. Where single accessible parking spaces are provided, they shall be 14' wide and lined to provide a 9-foot parking area and a 5-foot loading and unloading access aisle on the passenger side of the vehicle. The words "NO PARKING" shall be painted on the ground within each 5-foot loading and unloading access aisle. This notice shall be painted in white letters not less than 12" high and located so that it is visible to traffic enforcement officials. (1129B.3.1, Fig 11B-18B)
 8. When more than one accessible parking space is provided in lieu of providing a 14-foot-wide space for each parking space, two spaces can be provided within a 23-foot-wide area lined to provide a 9-foot parking area on each side of a 5-foot loading and unloading access aisle in the center. The words "NO PARKING" shall be painted on the ground within each 5-foot loading and unloading access aisle. This notice shall be painted in white letters not less than 12" high and located so that it is visible to traffic enforcement officials. (1129B.3.1, Fig 11B-18A & 18C)
 9. One in every eight accessible spaces, but not less than one, shall be served by an access aisle 96" wide minimum placed on the side opposite the driver's side when the vehicle is going forward into the parking space and shall be designated "van accessible". All such spaces may be grouped on one level of a parking structure. (1129B.3.2, Fig. 11B-18A, 18B, & 18C)
 10. The minimum length of an accessible parking space shall be 18'. (1129B.3.1, Fig 11B-18A, 18B, & 18C)
 11. Accessible parking spaces shall be so located that persons with disabilities are not compelled to wheel or walk behind parked cars other than their own. Ramp shall not encroach into any accessible parking space or the adjacent access aisle. The maximum cross slope in any direction of an accessible parking space and adjacent access aisle shall not exceed 2%. (1129B.3.3)
 12. Surface slopes of accessible parking spaces shall be the minimum possible and shall not exceed one unit vertical to 50-units horizontal (2% slope) in any direction. (1129B.3.4)
 13. In each parking area, a bumper or curb shall be provided and located to prevent encroachment of cars over the required width of walkways. (1129B.3.3, Fig 11B-18A, 18B, & 18C)
 14. Pedestrian ways which are accessible to people with disabilities shall be provided from each such parking space to related facilities, including curb cuts or ramps as needed. (1129B.3.3, Fig 11B-18A, 18B, & 18C)
 15. Each parking space reserved for persons with disabilities shall be identified by a reflectorized sign permanently posted immediately adjacent to and visible from each stall or space, consisting of the International Symbol of Accessibility in white on a dark blue background. The sign shall not be smaller than 70 sq. in. in area and, when in a path of travel, shall be posted at a minimum height of 80" from the bottom of the sign to the parking space finished grade. (1129B.4, Fig 11B-18A, 18B, & 18C)
 16. Signs to identify accessible parking spaces may be centered on a wall at the interior end of the parking space. (1129B.4)
 17. Van accessible parking spaces shall have an additional sign stating "Van Accessible" mounted below the symbol of accessibility. (1129B.4)



18. An additional sign shall also be posted in a conspicuous place at each entrance to off-street parking facilities, or immediately adjacent to and visible from each stall or space. The sign shall be not less than 17" by 22" in size with lettering not less than 1" in height, which clearly and conspicuously states the following: (1129B.4)

"Unauthorized vehicles parked in designated accessible spaces not displaying distinguishing placards or license plates issued for persons with disabilities may be towed away at owner's expense. Towed vehicles may be reclaimed at _____ or by telephoning _____. " (Blank spaces are to be filled in with appropriate information as a permanent part of the sign.)
 19. The surface of each accessible parking space or stall shall have a surface identification duplicating either of the following schemes: (1129B.4, Fig 11B-18A, 18B, & 18C)
 - a. By outlining or painting the stall or space in blue and outlining on the ground in the stall or space in white or suitable contrasting color a profile view depicting a wheelchair with occupant; OR
 - b. By outlining a profile view of a wheelchair with occupant in white on blue background. The profile view shall be located so that it is visible to a traffic enforcement officer when a vehicle is properly parked in the space and shall be 36" high by 36" wide.
 20. All entrances to and vertical clearances within parking structures shall have a minimum vertical clearance of 8'-2" where required for accessibility to accessible parking spaces. (1130B)
3. Provide minimum vertical clearance of 114" at accessible passenger loading zones and along at least one vehicle access route to such areas from site entrances and exits. (1131B.2.2)
 4. Valet parking facilities shall provide a passenger loading zone complying with Section 1131B.2 and shall be located on an accessible route of travel to the entrance of the facility. The parking space requirements of Section 1129B through 1130B apply to facilities with valet parking. (1131B.3)
 5. Where provided, bus stop pads shall have a firm, stable surface with a minimum clear length of 96" (measured from the curb or roadway edge) and a minimum clear width of 60" (measured parallel to the vehicle roadway) to the maximum extent allowed by legal or site constraints. Bus stop pads shall connect to streets, sidewalks or pedestrian paths as part of an accessible route. Newly constructed bus stop pads must provide a square curb surface between the pad and the road or other detectable warning approved by Department of State Architect in accordance with Section 1133B.8.5. Bus stop pads shall be at the same slope as the roadway in the direction parallel to the roadway and a maximum 2% slope perpendicular to the roadway. (1121B.2.1)
 6. Where provided, bus stop shelters shall be installed so as to permit a wheelchair user to enter the shelter from the public way and access a clear floor area of 30" by 48", completely within the shelter. Such shelters shall be connected by an accessible route to the boarding area. (1121B.2.1)

C. PASSENGER DROP-OFF & LOADING ZONES

1. When provided, passenger drop-off and loading zones shall be located on an accessible route of travel. (1131B.1)
2. Where provided, one passenger drop-off and loading zone shall provide an access aisle at least 60" wide and 20' long adjacent and parallel to the vehicle pull-up space. Vehicle standing spaces and access aisles shall be level with surface slopes not exceeding 1:50 (2%) in all directions. If there are curbs between the access aisle and the vehicle pull-up space, then a curb ramp shall be provided. (1131B.2.1, Fig 11B-24)

D. WALKS & SIDEWALKS

1. Walks and sidewalks subject to these regulations shall have a continuous common surface, not interrupted by steps or by abrupt changes in level exceeding 1/2". (1133B.7.1)
2. Walks and sidewalks shall be 48" minimum in width. (1133B.7.1, Fig 11B-27(a))
3. When changes in level not exceeding 1/2" occur, they shall be beveled with a slope no greater than one unit vertical to 2 units horizontal (50%), except that level changes not exceeding 1/4" may be vertical. (1133B.7.4, Fig 11B-5E(c) & (d))



4. When abrupt changes in level greater than 1/2" are necessary; they shall comply with the requirements for curb ramps. (1133B.7.4)
5. Walk and sidewalk surfaces shall be slip-resistant as follows: (1133B.7.1)
 - a. Surfaces with a slope of less than 6% gradient shall be at least a slip -resistant as that described as a medium salted finish. (1133B.7.1.1)
 - b. Surfaces with a slope of 6% or greater gradient shall be slip-resistant. (1133B.7.1.2)
6. When the slope in the direction of travel of any walk exceeds one vertical to 20 units horizontal (5% gradient), it shall comply with the provisions of Section 1133B.5. (1133B.7.3)
7. Walk and sidewalk surface cross slopes shall not exceed 1/4" per foot. (1133B.7.1.3)
8. All walks with continuous gradients shall have level areas at least 5' in length at intervals of at least every 400'. (1133B.7.6)
9. Walks shall be provided with a level area not less than 60" by 60" at a door or gate that swings toward the walk, and not less than 48" wide by 44" deep at a door or gate that swings away from the walk. (1133B.7.5, Fig 11B-26A & 26B)
10. Level area of walks shall extend 24" to the side of the strike edge of a door or gate that swings toward the walk. (1133B.7.5, Fig 11B-26B)
11. Walks, sidewalks, and pedestrian ways shall be free of gratings whenever possible. For gratings located in the surface of any of these areas, grid openings in gratings shall be limited to 1/2" in the direction of traffic flow. If gratings have elongated openings, they shall be placed so that the long dimension is perpendicular to the dominant direction of travel. (1133B.7.2, Fig 11B-7E(a))
1. Curb Ramps shall be constructed at each corner of street intersections where a pedestrian way crosses a curb. The preferred and recommended location for curb ramps is in the center of the crosswalk or each street corner. Where it is necessary to locate a curb ramp in the center of the curb return and the street surfaces are marked to identify pedestrian crosswalks, the lower end of the curb ramp shall terminate within such crosswalk areas. (1127B.5.1, Fig 11B-20C and 11B-22.)
2. Provide a curb ramp at . (1127B.5.1)
3. Curb ramps shall be a minimum of 4' in width and shall lie, generally, in a single sloped plane, with a minimum of surface warping and cross slope. (1127B.5.2)
4. The slope of curb ramps shall not exceed one unit vertical to 12 units horizontal (8.33% slope). (1127B.5.3)
5. Transitions from ramps to walks, gutters, or streets shall be flush and free of abrupt changes. (1127B.5.3)
6. Maximum slopes of adjoining gutters, road surface immediately adjacent to the curb ramp or accessible route, shall not exceed one unit vertical to 20 units horizontal (5% slope) within 4' of the top and bottom of the curb ramp. The slope of the fanned or flared sides of curb ramps shall not exceed one unit vertical to 10 horizontal (10% slope). (1127B.5.3)
7. A level landing 4' deep shall be provided at the upper end of each curb ramp over its full width to permit safe egress from the ramp surface, or the slope of the fanned or flared sides of the curb ramp shall not exceed one unit vertical to 12 units horizontal (8.33% slope). (1127B.5.4)
8. The surface of each curb ramp and its flared sides shall comply with Section 1124B, Ground and Floor Surfaces, and shall be of contrasting finish from that of the adjacent sidewalk. (1127B.5.5)
9. All curb ramps shall have a grooved border 12" wide at the level surface of the sidewalk along the top and each side approximately 3/4" on center. All curb ramps constructed between the face of the curb and the street shall have a grooved border at the level surface of the sidewalk. (1127B.5.6, Fig. 11B-19A & 19B)

E. CURB RAMPS

Curb Ramp is defined as “a sloping pedestrian way, intended for pedestrian traffic, which provides access between a walk or sidewalk to a surface located above or below an adjacent curb face”. (1102B)



10. Curb ramps shall have a detectable warning that extends the full width and depth of the curb ramp, excluding the flared sides, inside the grooved border. Detectable warnings shall consist of raised truncated domes with a diameter of nominal 0.9” at the base tapering to 0.45” at the top, a height of nominal 0.2”, and a center-to-center spacing of nominal 2.35”, in compliance with Figure 11B-23A. "Nominal" here shall be in accordance with Section 12-11A and B-102, State Referenced Standards Code. The detectable warning shall contrast visually with adjoining surfaces, either light-on-dark or dark-on-light. The material used to provide contrast shall be an integral part of the walking surface. The domes may be constructed in a variety of methods, including cast-in-place or stamped, or may be part of a prefabricated surface treatment. Only approved DSA-AC detectable warning products and directional surfaces shall be installed as provided in the California Code of Regulations (CCR), Title 24, Part 1, Articles 2, 3, and 4. (1127B.5.7)
11. Curb ramps shall be located or protected to prevent their obstruction by parked vehicles. (1127B.5.8)

F. PEDESTRIAN GRADE SEPARATIONS (OVERPASSES AND UNDERPASSES)

1. Pedestrian ramps on pedestrian grade separations shall comply with the requirements of Section 1133B.5 for ramps. (1128B)
2. Cross slopes of walking surfaces shall be the minimum possible and shall not exceed 1/4” per foot. The slope of any appreciably warped walking surface shall not exceed 1 unit vertical in 12 units horizontal in any direction. (1128B)
3. Where pedestrian grade separations cross streets or other vehicular traffic ways, and where a street level crossing can reasonably and safely be used by persons with disabilities, there shall be provided conforming curb ramps and a usable pathway. (1128B)

G. RAMPS (EXTERIOR OR INTERIOR)

1. Any path of travel shall be considered a ramp if its slope is greater than 1’ rise in 20’ of horizontal run. (1133B.5.1)

2. The maximum slope of a ramp that serves any exit way, provides access for persons with physical disabilities, or is in the accessible route of travel shall be 1’ rise in 12’ of horizontal run (8.3% gradient). The least possible slope shall be used for any ramp. (1133B.5.3)
3. The cross slope of ramp surfaces shall be no greater than 1:50. (1133B.5.3.1)
4. Pedestrian ramps shall have a minimum clear width of 48”, unless required to be wider by some other provision of this code. (1133B.5.2)(1133B.5.2)
5. Where a pedestrian ramp is the only exit discharge path serving entrances to buildings or when it serves an occupant load of 300 or more, the ramp shall have a minimum clear width of 60”. (1133B.5.2)
6. Level landings shall be provided at the top and bottom of each ramp. (1133B.5.4.1, Fig 11B-38 & 39)
7. Intermediate landings shall be provided at intervals not exceeding 30” of vertical rise and at each change of direction. (1133B.5.4.1, Fig 11B-38 & 39)
8. Top landings shall be not less than 60” wide and shall have a length of not less than 60” in the direction of ramp run. Landings at the bottom of ramps shall have a dimension in the direction of ramp run of not less than 72”. (1133B.5.4.2, Fig 11B-38 & 39)
9. Doors in any position shall not reduce the minimum dimension of the landing to less than 42” and shall not reduce the required width by more than 3” when fully open. (1133B.5.4.3, Fig 11B-39(b))
10. The width of the landing shall extend 24” past the strike edge of any door or gate for exterior ramps and 18” past the strike edge for interior ramps. (1133B.5.4.4, Fig 11B-39)
11. All ramp landings shall be level with maximum slope in any direction not to exceed 1/4” per foot (2.083% slope). (1133B.5.4.1, 1102B)
12. At bottom and intermediate landings, the width shall be at least the same as required for the ramp. (1133B.5.4.5, Fig 11B-38 & 39)



13. Intermediate and bottom landings at a change of direction in excess of 30 degrees shall have a dimension in the direction of ramp run of not less than 72" to accommodate the handrail extension. (1133B.5.4.6, Fig 11B-38)
14. Other intermediate landings shall have a dimension in the direction of ramp run of not less than 60". (1133B.5.4.7, Fig 11B-38)
15. Handrails are required on ramps that provide access if the ramp slope exceeds 1' rise in 20' of horizontal run (5% gradient), except that at exterior door landings, handrails are not required on ramps less than 6" rise or 72" in length. (1133B.5.5.1)
16. Handrails shall be placed on each side of each ramp, shall be continuous the full length of the ramp, shall be 34 to 38" above the ramp surface to the top of the handrails, shall extend a minimum of 1 foot beyond the top and bottom of the ramp, and shall parallel the floor or ground surface. Handrails shall always be continuous and the ends of handrails shall be either rounded or returned smoothly to the floor, wall or post. (1133B.5.5.1, Fig 11B-27(b) & (c))
17. The grip portion of handrails shall be not less than 1 1/4" nor more than 1-1/2" in cross sectional nominal dimension, or the shape shall provide an equivalent gripping surface, and all surfaces shall be smooth with no sharp corners. Handrails shall not rotate within their fittings. (1133B.5.5.1, Fig 11B-36)
18. Handrail projecting from a wall shall have a space of 1-1/2" between the wall and the handrail. (1133B.5.5.1, Fig 11B-36)
 - a. Handrails may be located in a recess if the recess is a maximum of 3" deep and extends at least 18" above the top of the rail. (1133B.5.5.1, Fig 11B-36)
 - b. Any wall or other surface adjacent to handrails shall be free of sharp or abrasive elements. Edges shall have a minimum radius of 1/8". (1133B.5.5.1, Fig 11B-36)
19. Where the ramp surface is not bounded by a wall, the ramp shall comply with one of the following requirements. (1133B.5.6, Fig 11B-27(b) & (c))
 - a. A guide curb a minimum of 2" in height shall be provided at each side of the ramp; (1133B.5.6.1) OR

- b. A wheel guide rail shall be provided, centered 3", plus or minus 1" above the surface of the ramp. (1133B.5.6.2)

20. In existing buildings or facilities where the extension of the handrail in the direction of the ramp run would create a hazard, the extension may be turned 90 degrees to the run of the ramp. (1133B.5.5.1.1, 1133B.4.2.4)
21. Ramps more than 30" above the adjacent ground shall be provided with guards that comply with Section 1013. Such guards shall be continuous from the top of the ramp to the bottom of the ramp. (1133B.5.7)

H. ENTRANCES & EXITS

Exit as defined is "that portion of a means of egress system which is separated from other interior spaces of a building or structure by fire-resistance-rated construction and opening protectives as required to provide a protected path of egress travel between the exit access and the exit discharge. Exits include exterior exit doors at ground level, exit enclosures, exit passageways, exterior exit stairs, exterior exit ramps and horizontal exits." (1002.1)

Public Way as defined is "a street, alley or other parcel of land open to the outside air leading to a street, that has been deeded, dedicated or otherwise permanently appropriated to the public for public use and which has a clear width and height of not less than 10'." (1002.1)

1. All entrances and exterior ground floor exit doors to buildings and facilities shall be made accessible to persons with disabilities. (1133B.1.1.1.1)
2. Revolving doors shall not be used as a required entrance for persons with disabilities. (1133B.2.3.3)
3. During periods of partial or restricted use of a building or facility, the entrances used for primary access shall be accessible to and usable by persons with disabilities. (1133B.1.1.1.2)
4. Recessed doormats shall be adequately anchored to prevent interference with wheelchair traffic. (1133B.1.1.1.3, Fig 11B-25)



5. All gates, including ticket gates, shall meet all applicable accessibility specifications of doors. (1133B.1.1.1.4)
6. Every required exit doorway shall be capable of opening at least 90 degrees, shall have a minimum clear opening of 32", and shall be of a size as to permit the installation of a door not less than 3' in width and not less than 6'-8" in height. (1133B.2.2)
7. The space between two consecutive door openings in a vestibule, serving other than a required exit stairway, shall provide a minimum of 48" of clear space from any door opening into such vestibule when the door is positioned at an angle of 90 degrees from its closed position. Doors in a series shall swing either in the same direction or away from the space between the doors. See Figures 11B-30 & 11B-31. (1133B.2.4.4)

I. DOORS

1. Door handles, pulls, latches, locks and other operating devices on doors required to be accessible shall not require tight grasping, tight pinching or twisting of the wrist to operate. Manually operated bolts or surface bolts are not permitted. The unlatching of any door or leaf shall not require more than one operation. (1008.1.8)
2. **Locks and latches.** Approved locks and latches shall be permitted to prevent operation of doors where any of the following exists(1008.1.9.3) :
 1. Places of detention or restraint.
 2. In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S, and in places of religious worship, the main exterior door or doors are permitted to be equipped with key-operated locking devices from the egress side provided:
 - 2.1. The locking device is readily distinguishable as locked;
 - 2.2. A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED. The sign shall be in letters 1 inch (25 mm) high on a contrasting background; and
 - 2.3. The use of the key-operated locking device is revocable by the building official for due cause.
3. Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts has no doorknob or surface-mounted hardware.
4. Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are operable from the inside without the use of a key or tool.
5. Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures.
3. Latching and locking doors that are hand activated and which are in a path of travel shall be operable with a single effort by lever type hardware, by panic bars, push-pull activating bars, or other hardware designed to provide passage without requiring the ability to grasp the opening hardware. (1133B.2.5.2)
4. Hand-activated door opening hardware shall be centered between 30" and 44" above the floor. (1133B.2.5.2)
5. When installed, doorways shall have a minimum clear opening of 32" with the door open 90 degrees. (1133B.1.1.1.1, Fig 11B -5B & 11B-33)
6. For hinged doors, the opening width shall be measured with the door positioned at an angle of 90 degrees from its closed position. (1133B.2.3, Fig 11B-5B)
7. Where a pair of doors is utilized, at least one of the doors shall provide a clear, unobstructed opening width of 32" with the leaf positioned at an angle of 90 degrees from its closed position. (1133B.2.3.1)
8. When an automatic or power assisted door operator is utilized to operate a pair of doors, at least one of the doors shall provide a clear, unobstructed opening width of 32" with the door positioned at an angle of 90 degrees from its closed position. Automatic doors shall comply with BHMA A156.10 or BHMA A156.19. (1133B.2.3.2)
9. Minimum maneuvering clearances at doors shall be as shown in Figure 11B-26A & 11B-26B. The floor or ground area within the required clearances shall be level and clear. (1133B.2.4.2)



10. There shall be a level and clear floor or landing on each side of a door. The level area shall have a length in the direction of door swing of at least 60" and the length opposite the direction of door swing of 48" as measured at right angles to the plane of the door in the closed position. Where the plane of the doorway is offset or located in an alcove a distance more than 8" measured from the plane of the doorway to the face of the wall, the door shall be provided with 60" maneuvering clearance for front approach. (1133B.2.4.2, 1133B.2.5.3, Fig 11B-26, Fig 11B-33a)
11. The width of the level area on the side to which the door swings shall extend 24" past the strike edge of the door for exterior doors and 18" past the strike edge for interior doors. Where the plane of the doorway is offset 8 or more" from any obstruction within 18" measured laterally on the latch side, the door shall be provided with maneuvering clearance for front approach. (1133B.2.4.3, 1133B.2.4.5, 1133B.2.5.3, Fig 11B-33(a))
12. Provide clear space of 12" past strike edge of the door on the opposite side to which the door swings if the door is equipped with both a latch and a closer. (Fig 11B-26(a))
13. The floor or landing shall be not more than 1/2" lower than the threshold of the doorway. (1133B.2.4.1)
14. The bottom 10" of all doors except automatic and sliding shall have a smooth, uninterrupted surface to allow the door to be opened by a wheelchair footrest without creating a trap or hazardous condition. Where narrow frame doors are used, a 10" high smooth panel shall be installed on the push side of the door, which will allow the door to be opened by a wheelchair footrest without creating a trap or hazardous condition. (1133B.2.6, Fig 11B-29)
15. Maximum effort to operate exterior and interior doors shall not exceed 5 pounds, with such pull or push effort being applied at right angles to hinged doors and at the center plane of sliding or folding doors. Compensating devices or automatic door operators may be utilized to meet the above standards. When fire doors are required, the maximum effort to operate the door may be increased to the minimum allowable by the appropriate administrative authority, not to exceed 15 lbf. (1133B.2.5)
16. When the door has a closer, then the sweep period of the closer shall be adjusted so that from an open position of 70 degrees, the door will take at least 3 seconds to move to a point 3" from the latch, measured to the landing edge of the door. (1133B.2.5.1)
17. Where turnstiles and crowd control barriers are utilized in a facility for the purpose of providing fully controlled access, such as where an admission price is charged, a door or gate that is accessible to persons with disabilities shall be provided adjacent to each turnstile exit or entrance. This alternate passageway shall be maintained in an unlocked condition during business hours and the door or gate shall not activate a publicly audible alarm system. The door or gate may be latched where all gates are restricted and controlled by an attendant and a sign is posted stating, "All gates are restricted and controlled by an attendant." The accessible door or gate shall provide the same use pattern. Where posts, rails, or other pedestrian controls are utilized to create crowd control aisles or lanes, a minimum aisle width not less than indicated in Figure 11B-5E (a) and (b) with 32" of clear opening. (1133B.2.3.4)

J. FLOORS AND LEVELS

Level area is defined as "a specified surface that does not have a slope in any direction exceeding 1/4" in one foot from the horizontal (2.083% gradient)." (1102B)

1. In buildings and facilities, floors of a given story shall be a common level throughout, or shall be connected by pedestrian ramps, passenger elevators, or special access lifts. (1120B.1)
2. Ground and floor surfaces along accessible routes and in accessible rooms and spaces, including floors, walks, ramps, stairs, and curb ramps, shall be stable, firm, and slip-resistant. (1120B.2 & 1124B.1)
3. Changes in level up to 1/4" may be vertical and without edge treatment. (1124B.2, Fig 11B-5E(c))
4. Changes in level between 1/4" and 1/2" shall be beveled with a slope no steeper than 1:2. (1124B.2, Fig 11B-5E(d))
5. If carpet or carpet tile is used on a ground or floor surface, it shall be securely attached; have a firm cushion, pad or



backing or no cushion or pad; and have a level loop, textured loop, level cut pile, or level cut/uncut pile texture. The maximum pile height shall be 1/2". Exposed edges of carpet shall be fastened to floor surfaces and have trim along the entire length of the exposed edge. Carpet edge trim shall comply with Section 1124B.2. (1124B.3, Fig 11B-7E)

6. If gratings are located on floors, then they shall have spaces no greater than 1/2" wide in one direction. If gratings have elongated openings, they shall be placed so that the long dimension is perpendicular to the dominant direction of travel. (1124B.4, Fig 11B-7E)

K. CORRIDORS & AISLES

1. Every corridor and hallway serving an occupant load of 10 or more shall not be less than 44" in width. (1133B.3.1)
2. Corridors and hallways serving an occupant load of less than 10 shall not be less than 36" in width. (1133B.3.1)
3. Corridors which are located on accessible route and exceed 200' in length shall: (1133B.3.2, Fig 11B-34)
 - a. Have a minimum clear width of 60"; OR
 - b. Have, at reasonable intervals, a 60" by 60" minimum wheelchair turning space or passing alcove; not to exceed 200'; OR
 - c. Have, at a central location, an intervening crossing or tee corridor, a minimum of 44" in width
4. Circulation aisles and pedestrian ways shall be sized according to functional requirements and in no case shall be less than 36" in clear width. (1105B.3.6)
5. Every portion of every building in which are installed seats, tables, merchandise, equipment, or similar materials shall be provided with aisles leading to an exit. (1133B.6.1)
6. Every aisle shall be not less than 36" wide if serving only one side, and not less than 44" wide if serving both sides. (1133B.6.2)

L. HAZARDS AND PROTRUDING OBJECTS

1. Abrupt changes in level, except between a walk or sidewalk and an adjacent street or driveway, exceeding 4" in a

vertical dimension, such as at planters or fountains located in or adjacent to walks, sidewalks, or other pedestrian ways, shall be identified by warning curbs projecting at least 6" in height above the walk or sidewalk surface to warn the blind of a potential drop off. (1133B.8.1)

2. When a guard or handrail is provided, no curb is required when a guide rail is provided centered 3" plus or minus 1" above the surface of the walk or sidewalk, the walk is 5% or less gradient or no adjacent hazard exists. (1133B.8.1, Fig 11B-27(c))
3. Objects projecting from walls with their leading edges between 27" and 80" above the finished floor shall protrude no more than 4" into walks, halls, corridors, passageways, or aisles. (1133B.8.6.1, Fig 11B-7A)
4. Objects mounted with their leading edges at or below 27" above the finished floor may protrude any amount into walks, halls, corridors, passageways, or aisles. (1133B.8.6.1, Fig 11B-7A)
5. Free-standing objects mounted on posts or pylons may overhang 12" maximum from 27" to 80" above the ground or finished floor. (1133B.8.6.1, Fig 11B-7B)
6. Protruding objects shall not reduce the clear width of an accessible route or maneuvering space. (1133B.8.6.1, FIG 11B-7D)
7. Walks, halls, corridors, passageways, aisles, or other circulation spaces shall have 80" minimum clear headroom. (1133B.8.6.2, Fig 11B-7A & 7C)
8. Any obstruction that overhangs a pedestrian way shall be a minimum of 80" above the walking surface as measured from the bottom of the obstruction. (1133B.8.2, Fig 11B-28)
9. Where a guy support is used parallel to a path of travel, including, but not limited to sidewalks, a guy brace, sidewalk guy or similar device shall be used to prevent an overhanging obstruction as defined. (1133B.8.2)
10. If a walk crosses or adjoins a vehicular way, and the walking surfaces are not separated by curbs, railings, or other elements between the pedestrian areas and vehicular areas, the boundary between the areas shall be defined by a



continuous detectable warning which is 36” wide, complying with Section 1121B.3.1, Item 8(a). (1133B.8.5)

11. Transit boarding platforms shall conform to the requirements of Section 1121B.3.1, Item 8(b). Only approved DSA/AC detectable warning products and directional surfaces shall be installed as provided in the California Code of Regulations, Title 24, Part 1, Articles 2, 3, and 4. (1133B.8.4 & 1133B.8.5)

M. STAIRWAYS

1. Stairways shall have handrails on each side, and every stairway required to be more than 88” in width shall be provided with not less than one intermediate handrail for each 88” of required width. Intermediate handrails shall be spaced approximately equally across the entire width of the stairway. Handrails shall be continuous along both sides of the stairway. (1133B.4.1.1)
2. The top of handrail gripping surface shall be mounted 34 to 38” above the nosing of the treads. (1133B.4.2.1, Fig 11B-35)
3. Handrails shall extend a minimum of 12” beyond the top nosing and 12” plus the tread width beyond the bottom nosing and ends shall be returned or terminate in newel posts or safety terminals. (1133B.4.2.2, 1133B.4.2.3, Fig 11B-35, 37)
4. The handgrip portion of handrails shall be not less than 1-1/4” or more than 1-1/2” in cross-sectional nominal dimension or the shape shall provide an equivalent gripping surface. The handgrip portion of handrails shall have a smooth surface with no sharp corners. Gripping surfaces (top or sides) shall be uninterrupted by newel posts, other construction elements, or obstructions. Any wall or other surface adjacent to the handrail shall be free of sharp or abrasive elements. Edges shall have a minimum radius of 1/8”. (1133B.4.2.6, Fig 11B-36)
5. The orientation of at least one handrail shall be in the direction of the run of the stair and perpendicular to the direction of the stair nosing, and shall not reduce the minimum required width of stairs. (1133B.4.2.4)
6. Handrails projecting from a wall shall have a space of 1-1/2” between the wall and the handrail. Handrails may be located in a recess if the recess is a maximum of 3” deep and extends at least 18” above the top of the rail. Handrails shall not rotate within their fitting. (1133B.4.2.5, Fig 11B-36)
7. The upper approach and the lower tread of each stair shall be marked by a strip of clearly contrasting color at least 2” wide placed parallel to and not more than one” from the nose of the step or landing to alert the visually impaired. The strip shall be of material that is at least as slip resistant as the other treads of the stair. (1133B.4.4, Fig 11B-35)
8. Where stairways occur outside a building, the upper approach and all treads shall be marked by a strip of clearly contrasting color at least 2” wide and placed parallel to and not more than 1” from the nose of the step or landing to alert the visually impaired. The strip shall be of a material that is at least as slip-resistant as the other treads of the stair. A painted strip shall be acceptable. (1133B.4.4, Fig 11B-35)
9. All tread surfaces shall be slip-resistant. Weather exposed stairs and their approaches shall be designed so that water will not accumulate on walking surfaces. Treads shall have smooth, rounded, or chamfered exposed edges, and no abrupt edges at the nosing (lower front edge). (1133B.4.5.1, Fig 11B-35)
10. The nosing shall not project more than 1-1/2” past the face of the riser below. (1133B.4.5.2, Fig 11B-35)
11. Open risers are not permitted. On any given flight of stairs, all steps shall have uniform riser height and uniform tread widths consistent with 1133B.4. Stair treads shall be no less than 11” deep, measured from riser to riser. Risers shall be sloped or the underside of the nosing shall have an angle not less than 60 degrees from the horizontal. (1133B.4.5.3, Fig 11B-35)
12. Tactile floor designation signs that comply with Section 1117B.5.1 shall be located at each floor level landing in all enclosed stairways in buildings two or more stories in height to identify the floor level. At exit discharge level, the sign shall include a raised five-pointed star located to the left of the identifying floor level. The outside diameter of the star shall be the same as the height of the raised characters. (1133B.4.3)



N. CONTROLS & OPERATING MECHANISMS

1. Controls and operating mechanisms in accessible spaces, along accessible routes or as part of accessible elements and those in Section 109.1 are required to be accessible. (1117B.6.1)
2. Clear floor space complying with Section 1118B.4 that allows a forward or parallel approach by a person using a wheelchair shall be provided at controls, dispensers, receptacles, and other operable equipment. (1117B.6.2)
3. The highest and lowest operable part of all controls, dispensers, receptacles, and other operable equipment shall be placed within one of the reach ranges specified in Sections 1118B.5 and 1118B.6. Electrical and communication system receptacles on walls shall be mounted no less than 15" above the floor. (1117B.6.3)
4. Controls and operating mechanisms shall be operable with one hand and shall not require tight grasping, punching, or twisting of the wrist. To force required to activate controls shall be no greater than 5 pounds of force. (1117B.6.4)
5. For accessible lavatories, faucet controls and operating mechanisms shall be operable with one hand and shall not require grasping, pinching, or twisting of the wrist. The force required to active faucet controls and operating mechanisms shall be no greater than 5 lbf. Lever-operated, push-type, and electronically controlled mechanisms are examples of acceptable designs. Self-closing valves are allowed if the faucet remains open for at least 10 seconds. (1115B.4.3)

O. SPACE ALLOWANCE & REACH RANGES

1. The minimum clear floor or ground space required to accommodate a single, stationary wheelchair and occupant is 30" by 48". The minimum clear floor or ground space for wheelchairs may be positioned for forward or parallel approach to an object. Clear floor or ground space for wheelchairs may be a part of the knee space required under some objects. (1117B.2.3, 1118B.4.1, Fig 11-B-5A)
2. One full unobstructed side of the clear floor or ground space for a wheelchair shall adjoin or overlap an accessible route or adjoin another wheelchair clear floor space. If a

clear floor or ground space is located in an alcove or otherwise confined on all or part of three sides, additional maneuvering clearances shall be provided. (1117B.2.4, 1118B.4.2, Fig 11-B-5A)

3. The space required for a wheelchair to make a 180 degrees turn is a clear space of 60" diameter or a T-shaped space. (1118B.3, Fig 11B-12(a) & (b))
4. The minimum clear width required for a wheelchair to turn around an obstruction shall be 36" where the obstruction is 48" or more in length and 42" and 48" where the obstruction is less than 48" in length. (Fig 11B-5E)
5. The minimum clear width for single wheelchair passage shall be 32" at a point and 36" continuously. (1118B.1, Fig 11B-10)
6. The minimum width for two wheelchairs to pass is 60". (1118B.2, Fig 11B-11)
7. If the clear floor space only allows forward approach to an object, the maximum high forward reach allowed shall be 48". See Figure 11B-5C(a). The minimum low forward reach is 15". If the high forward reach is over an obstruction, reach and clearances shall be as shown in Figure 11B-5C(b). (1118B.5)
8. If the clear floor space allows parallel approach by a person in a wheelchair, the maximum high side reach allowed shall be 54" and the low side reach shall be no less than 9" above the floor as shown in Figures 11B-5D(a) & (b). If the side reach is over an obstruction, the reach and clearances shall be as shown in Figure 11B-5D(c). (1118B.6)

P. EMPLOYEE WORK AREAS & WORK STATIONS

Work Station is defined as "an area defined by equipment and/or work surfaces intended for use by employees only, generally for one or a small number of employees at a time..." (1102B)

1. Employee areas shall conform to all requirements of the Division of the State Architect - Access Compliance in the California Building Code, Plumbing Code, and Electrical Code. (1123B.1)



2. Specific workstations need only comply with aisle width and floors and levels, and entryways shall be 32” in clear width. Aisles shall not be less than 36” if serving only one side, and not less than 44” wide if serving both sides. (1123B.2, 1133B.6.2)
3. Employee work areas shall be accessible by means of 36” minimum aisle and 32” minimum clear opening door width. (1105B.3.2.3)

Q. FIXED OR BUILT- IN SEATING, TABLES & COUNTERS

1. Where fixed or built-in seating, tables, or counters are provided for the public, and in general employee areas, 5% but never less than one must be accessible, as required in Section 1122B. (1122B.1)
2. If seating spaces for persons in wheelchairs are provided at fixed tables or counters, clear floor space complying with Section 1118B.4 shall be provided. Such clear floor space shall not overlap knee space by more than 19”. (1122B.2, Fig 11B-13)
3. If seating for persons in wheelchairs is provided at fixed tables or counters, knee spaces at least 27” high, 30” wide, and 19” deep shall be provided. (1122B.3, Fig 11B-13)
4. The tops of tables and counters shall be 28” to 34” from the floor or ground. (1122B.4)
5. Where a single counter contains more than one transaction station, such as a bank counter with multiple teller windows or a retail sales counter with multiple cash register stations, at least 5%, but never less than one of each type of station shall be located at a section of counter that is at least 36” long and no more than 28 to 34” high. (1122B.4)

R. SIGNS & IDENTIFICATION

California’s standards for signage are more stringent and are significantly larger and wider than Federal law, Americans with Disabilities Act (ADA) Section 4.30. (1117B.5)

The International Symbol of Accessibility shall be the standard used to identify facilities that are accessible to and usable by

physically disabled persons as set forth in Title 24 and as specifically required in this Section. (1117B.5.8.1, Fig 11B-6)

1. The International Symbol of Accessibility shall consist of a white figure on a blue background. The blue shall be equal to Color No. 15090 in Federal Standard 595B. (1117B.5.8.1.1)
2. All building and facility entrances that are accessible to and usable by persons with disabilities and at every major junction along or leading to an accessible route of travel shall be identified with a sign displaying the International Symbol of Accessibility and with additional directional signs, as required, to be visible to persons along approaching circulation paths. (1117B.5.8.1.2. & 1127B.3)
3. When permanent identification is provided for rooms and spaces of a building or site, raised letters shall be provided and shall be accompanied by Braille in conformance with Section 1117B.5.2 through 1117B.5.7. Signs shall be installed on the wall adjacent to the latch outside of the door. Where there is no wall space on the latch side, including at double leaf doors, signs shall be placed on the nearest adjacent wall, preferably on the right. Mounting height shall be 60” above the finished floor to the centerline of the sign. Mounting location shall be determined so that a person may approach within 3 inches of signage without encountering protruding objects or standing within the swing of a door. (1117B.5.1, 1117B.5.7)
4. When signs direct to or give information about permanent rooms and functional spaces of a building or site, they shall comply with Sections 1117B.5.2, 1117B.5.3, 1117B.5.4. Means of egress signs and identification for visual exit signs, graphics, illumination, power source, tactile exit signage, tactile stair level identification and special egress control devices shall comply with Sections 1003.2.8.1, 1003.2.8.5, 1003.2.9, 1003.2.10 and 1003.3.1.10. (1117B.5.1.2)
5. When raised characters or when pictogram symbols are used, they shall conform to the following: (1117B.5.5)
 - a. Characters on signs shall be raised or recessed 1/32” minimum and shall be sans - serif uppercase characters accompanied by Grade 2 Braille complying with section 1117B.5.6. (1117B.5.5.1)
 - b. Raised characters or symbols shall be a minimum of 5/8” high and a maximum of 2” high. (1117B.5.5.2)



- c. Pictorial symbol signs (pictograms) shall be accompanied by the verbal description placed directly below the pictogram. The outside dimension of the pictogram field shall be a minimum of 6" in height. (1117B.5.5.3)
 - d. Characters and Braille shall be in a horizontal format. Braille should be placed a minimum of 3/8" and a maximum of 1/2" directly below the tactile characters; flush left or centered. When tactile sign is multi-lined, all Braille shall be placed together below all lines of tactile text. (1117B.5.5.4)
- 6. Characters on signs shall have a width-to-height ratio of between 3:5 and 1:1 and a stroke width-to-height ratio between 1:5 and 1:10. (1117B.5.3)
 - 7. Characters, symbols and their background shall have a non-glare finish. Characters and symbols shall contrast with their background, either light characters on a dark background or dark characters on a light background. (1117B.5.2)
 - 8. Characters and numbers on signs shall be sized according to the viewing distance from which they are to be read. The minimum height is measured using an upper case "X". Lower case characters are permitted. For signs suspended or projected above the finish floor in compliance with Section 1133B.8.6, the minimum character height shall be 3". (1117B.5.4)
 - 9. Contracted Grade 2 Braille shall be used wherever Braille is required in other portions of these Standards. Dots shall be 1/10" on centers in each cell with 2/10" space between cells. Dots shall be raised a minimum of 1/40" above the background. (1117B.5.6)
 - 10. Pole supported pedestrian traffic control buttons shall be identified with color coding consisting of a textured horizontal yellow band 2" in width encircling the pole, and a 1" wide dark border band above and below this yellow band. Color-coding should be placed immediately above the control button. Control buttons shall be located no higher than 48" above the surface adjacent to the pole. (1117B.5.9)

S. ELECTRICAL

- 1. The highest operable part of all controls, dispensers, receptacles and other operable equipment shall be installed at an accessible location meeting the clearances and reach range requirements of Section 1118B.5 and 1118B.6 and not less than 15" above the floor or working platforms. (1117B.6.3)
- 2. The center of the grip of the operating handle of controls or switches intended to be used by the occupant of the room or area to control lighting and receptacle outlets, appliances, or cooling, heating, and ventilating equipment shall be 48" above the floor or working platform. (1117B.6.5.1)
- 3. The center of electrical receptacle outlets on branch circuits of 30 amperes or less shall be installed not more than 48" nor less than 14" above the floor or working platform. (1117B.6.5.2)

T. NOTIFICATION APPLIANCES FOR THE HEARING IMPAIRED

NOTE: If emergency warning systems are provided, they shall include both audible alarms and visual alarms complying with NFPA 72 and Chapter 9, Sections 907.9.1 and 907.9.2. (1114B.2)

- 1. Approved notification appliances for the hearing and visually impaired shall be installed in accordance with the provisions of NFPA 72 in the following areas:
 - a. Restrooms
 - b. Corridors
 - c. Music practice rooms
 - d. Band rooms
 - e. Gymnasiums
 - f. Multipurpose rooms
 - g. Occupational shops
 - h. Occupied rooms where ambient noise impairs hearing of the fire alarm
 - i. Lobbies
 - j. Meeting rooms
 - k. Any other area for common use

U. ADDITIONAL MISCELLANEOUS REQUIREMENTS



1. Qualified historical buildings shall comply with the State Historical Building Code, Part 8, Title 24, of the California Code of Regulations as printed in Part 2 of Title 24. (1119B & 1135B.1)
2. When a commercial facility is located in a private Residence, the portion of the residence used exclusively as a residence is not covered by Chapter 11B, except as required by 1111B.5, but that portion used both for the commercial facility and for residential purposes is covered by the new construction and alteration requirements of this code. (1101B.6.1)
3. The portion of the residence covered extends to those elements used to enter the commercial facility, including the homeowner's front sidewalk, if any, the door or entry way, and hallways; and those portions of the residence, interior or exterior, available to or to be used by employees or visitors of the commercial facility, including sanitary facilities. (1101B.6.2)

V. CLEANER AIR SYMBOL

1. Strictly for publicly funded facilities or any facilities leased or rented by State of California, not concessionaries. This symbol shall be the standard used to identify a room, facility and paths of travel that are accessible to and usable by people who are adversely impacted by airborne chemicals or particulate(s) and/or the use of electrical fixtures and/or devices. When used, the symbol shall comply Sections 1117B.5.11.1, 1117B.5.11.2, and 1117B.5.11.3 (1117B.5.11, Fig 11B-40)

